

ER-00168
TX 52552

STATE OF TEXAS WATER WELL REPORT

✓ 71 00006 7057

1) Owner: BEYER, ROYCE Address: 15815 HEIMER City: SAN ANTONIO State: TX ZIP: 78232
2) LOCATION OF WELL:
County: GILLESPIE 3.5 miles in SE direction from WILLOW CITY POST OFFICE

LEGAL DESCRIPTION:

SEE ATTACHED MAP: 87087

Section No.: Block No.: Township:
Abstract No.: Survey Name:
Distance and direction from two intersecting section or survey lines:

3) TYPE OF WORK: 4) PROPOSED USE: 5) DRILLING METHOD:
NEW WELL DOMESTIC AIR ROTARY/HAMMER

6) WELL LOG: 87087 DIAMETER OF HOLE 7) BOREHOLE METHOD:
DIAMETER FROM TO OPEN HOLE
6" 0 420 IF GRAVEL... FROM FT TO FT
FROM FT TO FT

Date Drilled: 05/16/87

GEOLOGICAL DESCRIPTION:

8) CASING, BLANK PIPE, AND WELL SCREEN DATA:

FROM	TO	DESCRIPTION	DIA	NEW/USED	DESCRIPTION	FROM	TO	GAGE CASING SCREEN
0	2	TOPSOIL	6"	N	PVC CASING	+2	82	SCH40
2	11	CALICHE-WHITE/YELLOW						
11	20	CLAY-BROWN						
20	23	SAND						
23	33	CLAY-BROWN, SANDY						
		GRAVEL						
33	40	LIMESTONE-BROWN						
		CLAY-BROWN						
40	72	CLAY-RED						
		LIMESTONE LEDGES						
72	82	SANDSTONE, BROWN W/CLAY						
82	110	HICKORY Ss, GRAY AND BROWN						
110	247	SANDSTONE, GRAY GLAUCONITIC						
247	420	SANDSTONE, RED AND WHITE						

9) CEMENTING DATA:

Cemented from 3 FT. TO 82 FT.
FT. TO FT.

Method used: GROUT
Cemented by: VIRDELL DRILLING INC

10) SURFACE COMPLETION:
PITLESS ADAPTER USED

11) WATER LEVEL:

STATIC LEVEL : 73' FT. DATE 05/16/87
ARTESIAN FLOW: 6PM. DATE / /

12) PACKERS: TYPE DEPTH

13) TYPE PUMP:

SUBMERSIBLE
DEPTH TO PUMP: 240'

14) WELL TEST:

ESTIMATED
YIELD: 100 GPM WITH FT DRAWDOWN AFTER HRS

15) WATER QUALITY:

TYPE OF WATER: GOOD DEPTH OF STRATA: 100-420
NO STRATA OF UNDESIRABLE WATER PENETRATED

NO CHEMICAL ANALYSIS MADE

COMPANY NAME: VIRDELL DRILLING INC. WATER WELL DRILLER'S LICENSE NO.: 240 (1900) 2665
ADDRESS: 111 E. GRAYSON ST. CITY: LLANO STATE: TX ZIP CODE: 78643

(signed)

(signed)

6/28/87