

FM 51

608 VEAL STATION RD.
NEW WATER WELL
MARCH 1, 2022
13 GPM

JANUARY

VEAL STATION RD

1140 FT

1160 FT

1150 FT

1150 FT

1740 FT

STATE OF TEXAS WELL REPORT for Tracking #600487

Owner:	MDB	Owner Well #:	1
Address:	329 SUGAR TREE LIPAN, TX 76462	Grid #:	32-03-7
Well Location:	604 VEAL STATION RD SPRINGTOWN, TX 76082	Latitude:	32° 54' 56.09" N
Well County:	Parker	Longitude:	097° 42' 43.6" W
		Elevation:	No Data
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Start Date: **1/28/2022** Drilling End Date: **1/28/2022**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	8	0	200

Drilling Method: **Air Rotary**

Borehole Completion: **Filter Packed**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Filter Material</i>	<i>Size</i>
Filter Pack Intervals:	120	200	Gravel	

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks & material)</i>
Annular Seal Data:	1	10	Cement 4 Bags/Sacks
	105	120	Bentonite 3 Bags/Sacks

Seal Method: **Poured**

Sealed By: **Driller**

Distance to Property Line (ft.): **50**

Distance to Septic Field or other
concentrated contamination (ft.): **No Data**

Distance to Septic Tank (ft.): **NOT INSTALLED**

Method of Verification: **No Data**

Surface Completion: **Surface Sleeve Installed**

Surface Completion by Driller

Water Level: **No Data on 2022-01-28**

Packers: **No Data**

Type of Pump: **Submersible** Pump Depth (ft.): **160**

Well Tests: **Yield: 14 GPM with 15 ft. drawdown after 1 hours**

Water Quality:

<i>Strata Depth (ft.)</i>	<i>Water Type</i>
120 - 185	No Data

Chemical Analysis Made: **No**

Did the driller knowingly penetrate any strata which
contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **KELVIN'S WATER WELLS**
2022 E. HWY 199
SPRINGTOWN, TX 76082

Driller Name: **E. DEIONNE MILES**

License Number: **54586**

Comments: **No Data**

Lithology:
DESCRIPTION & COLOR OF FORMATION MATERIAL

<i>Top (ft.)</i>	<i>Bottom (ft.)</i>	<i>Description</i>
0	1	TOP SOIL
1	10	YELLOW CLAY
10	120	GREEN SHALE
120	185	SAND
185	200	GREEN SHALE

Casing:
BLANK PIPE & WELL SCREEN DATA

<i>Dia (in.)</i>	<i>Type</i>	<i>Material</i>	<i>Sch./Gage</i>	<i>Top (ft.)</i>	<i>Bottom (ft.)</i>
4	Blank	New		1	120
4	Perforated or Slotted	New		120	200

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

Texas Department of Licensing and Regulation
P.O. Box 12157
Austin, TX 78711
(512) 334-5540

STATE OF TEXAS WELL REPORT for Tracking #600665

Owner:	MDB ENTERPRISES	Owner Well #:	1
Address:	329 SUGAR TREE LIPAN, TX 76462	Grid #:	32-03-7
Well Location:	608 VEAL STATION RD SPRINGTOWN, TX 76082	Latitude:	32° 54' 54.54" N
Well County:	Parker	Longitude:	097° 42' 42.19" W
		Elevation:	No Data
Type of Work:	New Well	Proposed Use:	Domestic

Drilling Start Date: **3/1/2022**

Drilling End Date: **3/1/2022**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	8	0	200

Drilling Method: **Air Rotary**

Borehole Completion: **Filter Packed**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Filter Material</i>	<i>Size</i>
Filter Pack Intervals:	120	200	Gravel	

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks & material)</i>
Annular Seal Data:	1	10	Cement 4 Bags/Sacks
	105	120	Bentonite 3 Bags/Sacks

Seal Method: **Poured**

Distance to Property Line (ft.): **50**

Sealed By: **Driller**

Distance to Septic Field or other
concentrated contamination (ft.): **No Data**

Distance to Septic Tank (ft.): **NOT INSTALLED**

Method of Verification: **No Data**

Surface Completion: **Surface Sleeve Installed**

Surface Completion by Driller

Water Level: **No Data on 2022-03-01**

Packers: **No Data**

Type of Pump: **Submersible**

Pump Depth (ft.): **160**

Well Tests: **Yield: 13 GPM with 15 ft. drawdown after 1 hours**

Water Quality:

<i>Strata Depth (ft.)</i>	<i>Water Type</i>
120 - 184	No Data

Chemical Analysis Made: **No**

Did the driller knowingly penetrate any strata which
contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **KELVIN'S WATER WELLS**
2022 E. HWY 199
SPRINGTOWN, TX 76082

Driller Name: **E. DEIONNE MILES**

License Number: **54586**

Comments: **No Data**

Lithology:
DESCRIPTION & COLOR OF FORMATION MATERIAL

<i>Top (ft.)</i>	<i>Bottom (ft.)</i>	<i>Description</i>
0	1	TOP SOIL
1	9	YELLOW CLAY
9	120	GREEN SHALE
120	184	SAND
184	200	GREEN SHALE

Casing:
BLANK PIPE & WELL SCREEN DATA

<i>Dia (in.)</i>	<i>Type</i>	<i>Material</i>	<i>Sch./Gage</i>	<i>Top (ft.)</i>	<i>Bottom (ft.)</i>
4	Blank	New		1	120
4	Perforated or Slotted	New		120	200

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

Texas Department of Licensing and Regulation
P.O. Box 12157
Austin, TX 78711
(512) 334-5540