



Hampshire Parcel Viewer



Hampshire Parcel Viewer



Flood map



Hampshire County Health Department

HC 71, Box 9

Augusta, WV 26704

(304) 496-9640

Fax: (304) 496-9650

March 7, 2006

Hampshire County Planning Commission
PO Box 883
Romney, WV 26757

Dear Sirs;

This office has reviewed a plat of survey for Delmas Kelly to approve a lot located off Huffman Road (approx. 2 miles on right) and further referenced as Mill Creek District, Tax Map 3, Parcel 21, Deed book 190, Page 440. This lot totals 9.282 acres.

All lots require a percolation test and a sewage disposal area where no development or structures other than the septic system shall be permitted. This lot is to be developed with an individual well and septic to serve a single-family dwelling.

Percolation test results are within limits as set forth by West Virginia CSR 16-1. Six feet soil observation holes indicate no restrictions due to water table or shallow bedrock within the designated sewage disposal area except as noted on the Health Department subdivision application.

The plat of survey dated March 7, 2006 is hereby approved for a Class II septic system by the Hampshire County Health Department. Any changes or revisions to the Health Department stamped and signed plat, or subsequent final plat approved based upon the approved plat, will make this approval null and void.

This approval is not a permit for individual water systems or individual sewer systems. Applications for permits must be made separately to the Hampshire County Health Department.

Sincerely,

A handwritten signature in cursive script, appearing to read "Denson Taketa".

Denson Taketa

cc: Ed Shoemaker
Delmas Kelly