

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas

WATER WELL REPORT

For TWDB use only
Well No. 41-40-20
Located on map
Received: 76 yes
alt

1) OWNER:
Person having well drilled L. C. Blackburn Address Star Rt. Evant, Texas 76525
(Name) (City) (State)
Landowner Same Address (City) (State)
(Name)

2) LOCATION OF WELL:
County Correll, 6 miles in E direction from Evant, Texas
(Name) (Town)
Locate by sketch map showing landmarks, roads, creeks, or
hiway number, etc.*

Evant, Tx. Hwy 84 Gatesville
Well North O Tx.
Residence
(Use reverse side if necessary)

3) TYPE OF WORK (Check):
New Well Domestic 4) PROPOSED USE (Check):
Reconditioning Plugging Irrigation Test Well Municipal Cable 5) TYPE OF WELL (Check):
Rotary Driven Dug
Bored

6) WELL LOG: 8" - to 52 ft., 6" to 280 ft., 5" to 303 ft.
Diameter of hole 8 in. Depth drilled 303 ft. Depth of completed well 303 ft. Date drilled 1-20-76
All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0 - 12	Surface	
12-26	Yellow Clay	
26-32	Gray Lime	
32-43	Sand (Paluxy Water)	
43-60	Gray Lime	
60-198	Glen Rose Lime	
198-235	Gray Lime	
235-265	Glen Rose Lime	
265-275	Soap Stone	
275-290	Sand - Trinity Water	
290-303	Gray Lime	

9) Casing:
Type: Old New Steel Plastic Other
Cemented from 0 ft. to 52 ft.
Diameter (inches) 7 1/2 From (ft.) 0 To (ft.) 52 Gage
5 0 280 160-W
4 280 303 Sch. 40
10) SCREEN:
Type Perforated Slotted
Diameter (inches) 4" From (ft.) 280 To (ft.) 303 Slot Size 3/8"

7) COMPLETION (Check):
(Use reverse side if necessary)
Straight wall Gravel packed Other
Under reamed Open Hole

8) WATER LEVEL:
Static level 260 ft. below land surface Date 1-20-76
Artesian pressure lbs. per square inch Date ft.
Depth to pump bowls, cylinder, jet, etc., 283 ft.
below land surface.

11) WELL TESTS:
Was a pump test made? Yes No If yes, by whom?
Yield: gpm with ft. drawdown after hrs.
Bailer test 15 gpm with 15 ft. drawdown after 1 hrs.
Artesian flow gpm
Temperature of water

12) WATER QUALITY:
Was a chemical analysis made? Yes No
Did any strata contain undesirable water? Yes No
Type of water? Trinity depth of strata 15

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME James W. Smith Water Well Drillers Registration No. 1558
(Type or Print)

ADDRESS 804 South Avenue J Clifton Texas 76634
(Street or RFD) (City) (State)

(Signed) James W. Smith James W. Smith Drilling
(Water Well Driller) (Company Name)

(817) 675-8169

Please attach electric log, chemical analysis, and other pertinent information, if available.

*Additional instructions on reverse side.