



**Hampshire County Health Department**

HC 71, Box 9

Augusta, WV 26704

(304) 496-9640 Fax: (304) 496-9650

April 29, 2004

Hampshire County Planning Commission  
66 North High Street  
Romney, WV 26757

Dear Sirs;

This office has reviewed a plat of survey for Andrew Garriss to create lot 15 located at Whispering Pines subdivision, and further referenced as Tax Map 8, Parcel 133, Deedbook 368, Page 584. This lot consists of 22.55 acres. All lots require a percolation test and a sewage disposal area of 10,000 square feet where no development or structures other than the septic system shall be permitted. This lot is to be developed with an individual well and septic to serve a single family dwelling.

Percolation test results are within limits as set forth by West Virginia CSR 16-1. Six foot soil observation holes indicate no restrictions due to water table or shallow bedrock within the designated sewage disposal area except as noted on the Health Department subdivision application.

The plat of survey dated is hereby approved by the Hampshire County Health Department. Any changes or revisions to the Health Department stamped and signed plat, or subsequent final plats approved based upon the approved plat, will make this approval null and void.

This approval is **not** a permit for individual water systems or individual sewer systems. Applications for permits must be made separately to the Hampshire County Health Department.

Sincerely

A handwritten signature in dark ink, appearing to read "Jim Kinder".

Jim Kinder R.S..

CC: Andrew Garriss

# REPORT SHEET

**FOR**

## PERCOLATION AND SIX FOOT HOLE TESTING

Subdivision Name Whispering Pines Lot #15 County Armstrong  
Total Number of Lots 40 Name of Applicant Keen Shultz  
Name of Certified Installer Responsible for Testing Jeffrey G. Miller  
Installer Certification No. 05482221 Installer Signature Jeffrey G. Miller

[illegible]

(Attach additional pages if needed)