



IMPROVEMENT PERMIT

Granville County Health Dept
Environmental Health
101 Hunt Drive
Oxford, NC 27565
Phone: (252) 492-5263 Fax: (252) 492-2361

For Office Use Only

*CDP File Number 375584 - 1
County ID Number: 096900310009
Evaluated For: NEW

PERMIT VALID UNTIL: 05/27/2027

***NOTE TO INSPECTIONS DIVISION:** Building Permits cannot be issued with this Improvement Permit.

Applicant: Oakwood Homes
Address: 2741 US1/158 Hwy
City: Henderson
State/Zip: NC 27581
Phone #: home: (252) 204-0919

Property Owner: John Hodges
Address: 8518 Charlie Stovall Rd
City: Roxboro
State/Zip: NC, 27573
Phone #:

Property Location & Site Information

Address/Road #: Charlie Stovall Rd Roxboro, NC Subdivision: Phase: NEW Lot:
27573
Structure: SINGLE FAMILY
of Bedrooms: 4
of People:
*Water Supply: NEW WELL

System Specifications

Initial System

*Site Classification: Provisionally Suitable

Design Flow: 480

Soil Application Rate: 0.3000

*System Classification/Description:

TYPE III G. OTHER NON-CONV. TRENCH SYSTEMS

*Proposed System:

25% REDUCTION

Minimum Trench Depth: 18 Inches

Maximum Trench Depth: 20 Inches

Septic Tank: 1000 Gallons

Pump Required ☐ Yes ☒ No ☐ May Be Required

Pump Tank: Gallons

Repair System Required: ☒ Yes ☐ No ☐ No, but has Available Space

Repair System

*Site Classification: Provisionally Suitable

Soil Application Rate: 0.300

*System Classification/Description:

TYPE III G. OTHER NON-CONV. TRENCH SYSTEMS

*Proposed System:

25% REDUCTION

Minimum Trench Depth: 18 Inches

Maximum Trench Depth: 20 Inches

Pump Required: ☐ Yes ☒ No ☐ May Be Required

Pump Tank: Gallons

No grading or construction activity is allowed in areas designated for system and repair without approval of Health Department

*Site Modifications

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

*Permit Conditions

Initial system laid out in field by REHS. Keep any part of septic min. 10' off house foundation. Driveway to not extend past what is shown on site plan (Must not encroach on septic). Min. 100' off all well's. Min. 10' off property lines with septic.

The Department and Local Health Department may impose conditions on the issuance and may revoke the permits for failure of system to satisfy the conditions, the rules, or this article. This permit is subject to revocation if the site plan, plat, or intended use changes (NCGS 130A-335(f)). The person owning or controlling the system location, installing, operation, maintenance, monitoring, reporting, and repair (1938(b)).

Authorized State Agent:

Bullock, Will

Date of Issue:

05/27/2022

Total Time: (HH:MM)

☒ Hand Drawing

☐ Import Drawing

****Site Plan/Drawing attached.****

Granville County Health Department
Environmental Health

Permit Number P-375584

Pin _____

☒ Improvement Permit

4 bdrn.

☐ Construction Authorization

S-267734

Site Sketch

Oakwood Nomer

Applicant's Name

Willie News

Authorized State Agent

Charlie Stoval Rd. (next to 8520)

Subdivision - Section - Lot

5/26/22

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to insure that proper grade is maintained.

