

APPLICATION FOR PRIVATE SEWAGE SYSTEM
CONSTRUCTION PERMIT AND LICENSE

DATE March 26 2002 PERMIT NO. 4210 FEE \$150.00

I, hereby make an application for a license to construct and operate a private sewage disposal system in Gillespie County, Texas.

OWNER Glenn & Polly Priess PHONE NO. (830) 990-9665

MAILING ADDRESS 100 Northwest Drive #18 Fredericksburg TX 78624

HOUSE NO. AND STREET ADDRESS 222 Metzger Road Fredericksburg TX 78624

SUBDIVISION, DESCRIBED LOCATION OR ATTACH A MAP/SKETCH

NAME Hartman Subdivision, Lot 1, Acks 1.826

SIZE ACREAGE OR TRACT 1.826 SECTION _____ BLOCK _____ LOT _____

DESCRIPTION OF STRUCTURE TO BE SERVED

House (☒) Mobile Home () Other _____

Commercial _____

(Type of Business)

Living Area (960) Bedrooms (3) Bathrooms (3) Disposal (-)

Washing Machine (☒) Dishwasher (☒) Water Softner () Other _____

Water Supply By: Public System () Community () Individual (☒)

DATE 3/28/02 INSPECTOR-SANITARIAN D. Ryan

Authorization is hereby given to the Private Sewage Facility, Gillespie County, Texas, Texas Department of Water Resources, the Texas State Department of Health Resources, or their agents or designees, singly or jointly, to enter upon the above described property for the purpose of making soil percolation tests, inspecting sewage systems, or for any reason consistent with the water quality program of the Texas Department of Water Resources, the Texas State Department of Health Resources and the Private Sewage Facility, Gillespie County, Texas.

(If signed by Owner, Authorized Agent, Contractor, provide name, address and phone #) Glenn Priess, 100 NW Dr. #18, Fredericksburg TX 78624 (830) 990-9665 (h)
Polly Priess (830) 990-3458 (w)

DATE 3-28-02 Signature of Owner or Authorized Agent

Authorization to proceed with construction will be provided after a joint (Owner or Installer and Inspector for the Private Sewage Facility, Gillespie County, Texas survey of the proposed site for the facility and analysis of percolation test data) (If Required)

THIS PERMIT TO CONSTRUCT IS VALID FOR 180 DAYS.

OFFICIAL USE ONLY

SITE INSPECTION OR PERCOLATION TEST

DATE _____ PERMIT NO. _____ FEE _____

TYPE SOIL - Rocky () Gravel () Sand () Other _____

SLOPE - Flat () Sloping () Other _____

PERCOLATION TEST RESULTS INCHES FALL/20 MINUTES

HOLES (1) _____ (2) _____ (3) _____ (4) _____ (5) _____ (6) _____

(7) _____ (8) _____ PERC. TEST AVERAGE _____

DATE _____ INSPECTOR-SANITARIAN _____
COMMENTS:

SCANNED

AUG 02 2002

CERTIFICATION OF APPROVAL

FINAL INSPECTION

DATE 04/03/02 PERMIT NO. _____ FEE _____

MANUFACTURER BUCHANAN SEPTIC TANKS

TANK #1 SN# 319 021 TANK #2 SN# _____

SIZE TANK #1 1250 GALS. TANK #2 _____ GALS. TYPE CONCRETE

ABSORPTION TRENCH (☒) LENGTH 400' WIDTH 3' (5' ORBIT)

ABSORPTION BED AREA () SQUARE FEET 2000 SQ. FT.

COMMERCIAL () PRIVATE RESIDENCE ()

INSTALLER OR CONTRACTOR ED MELCER

ADDRESS FBH TX 78624 PHONE # _____

DATE 04/03/02 FINAL INSPECTION MADE BY Dwight CBros

(INSPECTION IS REQUIRED AFTER TANK AND PIPES ARE INSTALLED, **BUT NOT COVERED**)
MAKE A SKETCH OF SYSTEM
(NOT TO SCALE)

