

JMA Wastewater Services, Inc.
P.O. Box 1101
Dripping Springs, TX 78620

Phone: (512) 801-8594

Fax: (512) 829-4407

www.jmaseptic.com jmaws.septic@gmail.com

To: Frank Walker
P.O. Box 2109
Wimberley, TX 78676

Printed 6/8/2022

Site: 4771 Fischer Store Road
Wimberley, TX 78676

512) 606-2277

Permit #: 2008-556

Customer ID: 1428

Agency: Hays County Development Services

Contract Dates: 10/15/2021 - 10/15/2022

County: Hays County

Scheduled Date: 6/15/2022

Inspection 4 of 3

Mfg / Brand: Aqua Klear - Aqua Klear

Aerator: AK5 BES 3

Installed: 10/1/2008

Treatment Type: Aerobic

Warranty End: 10/1/2010

Disposal: Surface Application

Service Type: Scheduled Inspection

☒ This counts as a type of "Scheduled Inspection"

Visit Date: 6/8/2022

Entered By: _

Method: Grab

Technician: James Preuss

Maint. Provider: James Ashman

Aerators: Operational

Filters: Operational

Irrigation Pumps: Operational

Disinfection Device: Operational

Chlorine Supply: Operational

Chlorine Residual: 0.1mg/L

Tank Lid / Riser: Secured

Electric Circuits: Operational

Distribution System: Operational

Sprayfield Veg: Operational

Alarm: Operational

Comments

☒ Service Completed

- Normal system operation. Root infiltration in tanks. Timer getting hard to turn to set. May need to be replaced in near future. -
Technician Secured the Tank Lid or Riser prior to leaving location.

Insp ID #: 62061

License Info: MP0000258 Expires: 9/30/2023

License Info: MT0001231 Expires: 10/31/2022

JMA Wastewater Services, Inc.
P.O. Box 1101
Dripping Springs, TX 78620

Phone: (512) 801-8594

Fax: (512) 829-4407

www.jmaseptic.com jmaws.septic@gmail.com

To: Frank Walker
P.O. Box 2109
Wimberley, TX 78676

Printed: 2/8/2022
Site: 4771 Fischer Store Road
Wimberley, TX 78676
(512) 626-2277

Permit #: **2008-556**

Customer ID: 1428

Agency: Hays County Development Services

Contract Dates: 10/15/2021 - 10/15/2022

County: Hays County

Scheduled Date: 2/15/2022

Inspection 4 of 3

Mfg / Brand: Aqua Klear - Aqua Klear

Aerator: AK5 BES 3

Installed: 10/1/2008

Treatment Type: Aerobic

Disposal: Surface Application

Service Type: Scheduled Inspection

☒ This counts as a type of "Scheduled Inspection"

Visit Date: 2/8/2022

Entered By: _

Method: Grab

Technician: James Preuss

Maint. Provider: James Ashman

Aerators: Operational

Filters: Operational

Irrigation Pumps: Operational

Disinfection Device: Operational

Chlorine Supply: Operational

Chlorine Residual: 0.1mg/L

Tank Lid / Riser: Secured

Electric Circuits: Operational

Distribution System: Operational

Sprayfield Veg: Operational

Alarm: Operational

Comments

☒ **Service Completed**

- Normal system operation. - Please add bleach to the liquid bleach chlorinator. Root infiltration in tanks. - Technician Secured the Tank Lid or Riser prior to leaving location.

Insp ID #: 79848

License Info: MP0000258 Expires: 9/30/2023

License Info: MT0001231 Expires: 10/31/2022