

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

DEC 14 1973

1. COUNTY <u>Richland</u>		CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		NAME <u>Sylvan</u>	
2. LOCATION - 1/4 Section <u>SW</u> Section <u>35</u> Township <u>11N</u> Range <u>2W</u>		3. OWNER AT TIME OF DRILLING <u>Christian Arne</u>			
OR - Grid or street no		Street name		ADDRESS <u>Rt 1</u>	
AND - If available subdivision name, lot & block no		POST OFFICE <u>Richland Center, Wis</u>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C I	FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT
		5			
CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN
	80				
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc)					

5. Well is intended to supply water for: Private Home

6. DRILLHOLE						9. FORMATIONS		
Dia (in)	From (ft)	To (ft)	Dia (in)	From (ft)	To (ft)	Kind	From (ft)	To (ft)
10	Surface	25				Clay	Surface	15
6	25	108				Sand/Gravel	15	30
7. CASING, LINER, CURBING, AND SCREEN						Soft Shale		
Dia (in)	Kind and Weight	From (ft)	To (ft)				30	34
10	Liner (Pulled Out)	Surface	25			Sand Rock	34	55
6	New T&C 18.97"	—	40			Water Bearing White Sand Rock	55	108
6" W.O. Steel Drive Shoe								

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft)	To (ft)	<input checked="" type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
Drill Cuttings	Surface	25	<input type="checkbox"/> Rotary - air w/drilling mud	<input type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with Air Water
			Well construction completed on <u>9-25</u> 19 <u>73</u>		

11. MISCELLANEOUS DATA			Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
Yield test:	<u>4</u> Hrs. at	<u>10</u> GPM	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level	<u>26</u> ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth to water level when pumping	<u>30</u> ft				
Water sample sent to <u>Madison</u> laboratory on. <u>9/28</u> 19 <u>73</u>					

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side

SIGNATURE <u>Joel Parkhurst</u> Registered Well Driller	COMPLETE MAIL ADDRESS <u>Sextonville, Wis</u>
--	---

COLIFORM TEST RESULT	do not write in space below	GAS - 48 HRS	CONFIRMED	REMARKS