



**ORIGINAL PERMIT APPLICANT(S)**

JUSTIN DAVIS

**APPROVED WELL LOCATION**

Water Division: 3      Water District: 20  
Designated Basin: N/A  
Management District: N/A  
County: ALAMOSA  
Parcel Name: N/A  
Physical Address: N/A

NW 1/4 NW 1/4 Section 26 Township 38.0 N Range 11.0 E New Mexico P.M.

**UTM COORDINATES (Meters, Zone:13, NAD83)**

Easting: 434102.0      Northing: 4152190.0

**PERMIT TO USE AN EXISTING WELL**

**ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT**

**CONDITIONS OF APPROVAL**

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(I) and the policy of the State Engineer dated April 9, 1985 for appropriation of groundwater tributary to the Rio Grande system.
- 4) Approved for the use of existing well, registered under permit no. 329712, as the only exempt well on 36.38 acres in the NW1/4 of the NW1/4, Section 26, Township 38 N, Range 11 East, NMPM, Alamosa County, as depicted in CDWR's online Mapping Tool (Map Viewer).
- 5) The issuance of this permit hereby cancels permit no. 329712.
- 6) The use of groundwater from this well is limited to washing, drinking and sanitary facilities as described in CRS 37-92-602(1)(c), for a commercial business. Water from this well shall not be used for lawn or landscape irrigation or for any other purpose outside the business building structure.
- 7) The pumping rate of this well shall not exceed 15 GPM.
- 8) The annual amount of groundwater to be withdrawn by this well shall not exceed 1/3 acre-foot (108,600 gallons).
- 9) Production from this well is limited to the confined aquifer. The reported depth of this well is 300 feet per well permit no. 329712.
- 10) The return flow from the use of this well must be through an individual wastewater disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 11) A totalizing flow meter must be installed on this well and maintained in good working order. Permanent records of all diversions must be maintained by the well owner (recorded at least annually) and submitted to the Division Engineer upon request.
- 12) This well shall be constructed not more than 200 feet from the location specified on this permit.

NOTICE: You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.)

Issued By KEVIN BOYLE

Date Issued: 2/9/2023

Expiration Date: N/A