

Dusty Underwood Plumbing & Septic, Inc.
1580 FM 273, Bonham, Texas 75418 United States
(903) 449-1677

Invoice 115061
Invoice Date 11/16/2022
Payment Term Due Upon Receipt
Due Date 11/16/2022

Billing Address
Evelyn Spaulding
4451 County Road 4410
Commerce, TX 75428 USA

Job Address
Evelyn Spaulding
4451 County Road 4410
Commerce, TX 75428 USA

Description of Work

Task #	Description	Quantity	Your Price	Your Total
BSM-1-A	1-Year Bronze Septic Membership	1.00	\$285.00	\$285.00

**Need a basic maintenance contract? Hey, we have you covered!
But look, even our base option blows away the competition.**

- ☒ 3 Septic System Inspections Per Year - Inspection Points Include Aerator, Pump, Chlorine Supply, Electrical Circuits, Distribution System, & Overall Condition of System Where Visible.
- ☒ County Filing Fee is Included - If the county requires a filing fee, we pay them at no extra charge to you.
- ☒ Inspection Contract & Reports sent to County - If the county requires reports, we provide them. If they don't we don't.
- ☒ Automatic Renewal - Tired of the hassle of renewing your contract once a annually, we can set you up with a hands off auto renewal.
- ☒ Monthly Billing Membership Plans Available - Don't want to pay all at once? We get it and we have monthly billing options for you.
- ☒ Membership Discounts - You get more with our Septic Maintenance Contracts, you get Membership Privileges including 10% OFF Services.
- ☒ Uniformed, Licensed, Professional, & Background Checked Technicians $\frac{1}{2}$ - No Plumbers Crack.
- ☒ Appointment Notifications W/ Technician Picture & Bio - Know your technicians and when he's in route to your home.
- ☒ Online Customer Content Portal - 24/7 Account Access at Your Fingertips. View Estimate, Invoices, Reports, and even make Payments.
- ☒ Flat Rate Pricing - Know the Price Before We do the Work!
- ☒ 24-Hour Emergency Service Available - Even the best maintained systems can break down on you and if your does we have you covered, period.
- ☒ Same Day Service Calls - Yes, We Are Going The Extra Mile For You. *****
- ☒ Financing Available - Sometimes You Just Need a covering those big ticket items, if you do we have financing for most services over \$1,000.
- ☒ Full Service Septic Company - If it Has to Do With Septic Systems We Have You Covered!
- ☒ Plumbing & Septic Company - Need a Plumber? Yes, We do Plumbing As Well!
- ☒ Insured - In this Business Can Happen and if it Ever Does, We are Insured


Sub-Total \$285.00
Total Due \$285.00
Balance Due \$285.00

Thank you for choosing Dusty Underwood Plumbing & Septic, Inc.

This invoice is agreed and acknowledged. Payment is due upon receipt. A service fee will be charged for any returned checks, and a financing charge of 1% per month shall be applied for overdue amounts.

I find and agree that all work performed by Dusty Underwood Plumbing & Septic, Inc. has been completed in a satisfactory and workmanlike manner. I have been given the opportunity to address concerns and/or discrepancies in the work provided, and I either have no such concerns or have found no discrepancies or they have been addressed to my satisfaction. My signature here signifies my full and final acceptance of all work performed by the contractor.

- *There is a one (1) year warranty on parts and labor
- *The price shown includes applicable sales and use tax



Job #118245

☐ Aerobic W/ Spray Inspection

Job Info

Date

2023-03-15

Technician

Noah Carr

Customer

Evelyn Spaulding

Phone

(407) 925-6923

Address

4451 County Road 4410, Commerce, TX 75428 USA

We thank you for choosing DUPS as your plumbing and septic professionals!

Access To Septic System

Access to property and septic system is required for inspection.

☒ Good Access

Membership Level

Bronze

Inspection List**Visually Inspect Control Panel**

We check your control panel components to help prevent malfunctions.

☒ No issues observed

Test Alarm Buzzer

Alarm buzzers audibly alert you to septic system issues.

☒ No issues observed

Test Alarm Light

Alarm lights visually alert you to septic system issues.

☒ No issues observed

Test Mute Test/Switch

A faulty test/mute switch can cause false alarms and a loss of function.

- ☒ No issues observed
-

Visually Inspect Irrigation Timer

We adjust your irrigation timer parameters as needed keeping you on track.

- ☒ No adjustment needed
-

Visually Inspect Conduits

We keep your conduits sealed preventing corrosive gasses from entering the control panel.

- ☒ Conduits sealed
-

Visually Inspect Air Pump Housing

We clean your air pump housing to allow proper fresh air flow around your air pump.

- ☒ Air pump housing was clean
-

Visually Inspect Air Pump

The air pump supplies the aerobic treatment unit with fresh air that the bacteria need to live and flourish.

- ☒ No issues observed
-

Visually Inspect Air Filter

We clean your air pump filter to maximize component efficiency and life span.

- ☒ Cleaned and reinstalled air filter
-

Visually Inspect Air Pump Air Flow

As air pumps age air flow often decreases which threatens the bacteria colonies and the treatment process.

- ☒ Good air flow
-

Visually Inspect Sanitary Sewer

Your sanitary sewer is responsible for distributing the sewage from the house to the septic system.

- ☒ No issues observed
-

Visually Inspect Pre-Treatment Tank Access

Watertight and secure tank access port risers, lids, and secondary lids are vital for the protection of our family and neighbors.

- ☒ Watertight and secure
-

Visually Inspect Pre-Treatment Tank Condition

Over time tanks deteriorate and may need repairs or replacement.

- ☒ No issues observed
-

Visually Inspect Pre-Treatment Tank Baffles

We rod your accessible baffles to help prevent drainage backups into the building.

- ☒ Baffles were clear
-

Visually Inspect Aerobic Treatment Unit Tank Access

Watertight and secure tank access port risers, lids, and secondary lids are vital for the protection of our family and neighbors.

- ☒ Watertight and secure

Visually Inspect Aerobic Treatment Unit Tank Condition

Over time tanks deteriorate and may need repairs or replacement.

- ☒ No issues observed

Visually Inspect Aerobic Treatment Unit Effluent Quality

Harsh chemicals, soaps, detergents, and overloading can cause the effluent quality to be jeopardized.

- ☒ Good (light brown/no odor)

Visually Inspect Aerobic Treatment Unit Air Movement

A steady flow of fresh air is needed to both mix and repopulate the effluent with oxygen needed to maintain the aerobic environment.

- ☒ Good mixing

Visually Inspect Clarifier Access

Watertight and secure tank access port risers, lids, and secondary lids are vital for the protection of our family and neighbors.

- ☒ Watertight and secure

Visually Inspect Effluent Filter

We clean your effluent filter to help prevent drainage backups into the building and allow organic matter to pass through without proper filtration.

- ☒ Clean filter

Visually Inspect Chlorinator

Your chlorinator doses the chlorine needed to disinfect the effluent prior to being sprinkled onto the lawn.

- ☒ No issues observed

Test Total Chlorine Residual Level

We measure the chlorine levels found in the pump tank effluent. We want to see traces chlorine in the effluent indicating that the effluent has been disinfected.

- ☒ Good residual (.1 PPM or more)

Visually Inspect Pump Tank Access

Watertight and secure tank access port risers, lids, and secondary lids are vital for the protection of our family and neighbors.

- ☒ Watertight and secure

Visually Inspect Pump Tank Condition

Over time tanks deteriorate and may need repairs or replacement.

- ☒ No issues observed

Visually Inspect Electrical Circuits

Extends life of system; ensures safety.

- ☒ No issues observed

Test Effluent Pump

We inspect your effluent pump in order to locate issues that could result in emergencies and backups if not resolved.

- ☒ No issues observed

Visually Inspect Effluent Pump Inlet Screen

We clean your effluent pump inlet screen to help maintain optimal performance and longevity.