



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 - 360.757.1400

Bellingham, WA Microbiology (b)
905 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.662.7602

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4945

Bend, OR Microbiology (e)
26332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.839.8425



Page 1 of 1

Drinking Water Report

Client Name: Jones Pump Company
29400 Santiam Hwy
Lebanon, OR 97355

Reference Number: **23-13107**

Report Date: 5/11/23

Approved By: bj,rap,spm

Authorized by:

Sarah P Miller
Sarah P Miller
Lab Manager, Corvallis

Project: Darrell Hunt
Field ID: Faucet at well
Sample Description: Larwood Dr/Zeleny Rd, Scio
Sample Date: 5/5/23 13:30

Lab Number: OR100009-26209
Date Received: 5/5/23
Sampled By: Glenda Hubbard
Sampler Phone:

CAS Number	Analyte	Result	MCL	Pass [^]	Lab	QL	Units	Analyzed
Coli-To-t	TOTAL COLIFORM	Absent		Pass	d	P/A	per 100m	5/7/23
68583-22-2	E. Coli	Absent		Pass	d	Y/N	per 100m	5/7/23
14797-55-8	NITRATE-N	ND	10	Pass	d	0.02	mg/L	5/5/23
7440-38-2	ARSENIC	ND	0.010	Pass	a	0.001	mg/L	5/8/23

Notation:

MCL = Maximum Contaminant Level, maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.

QL = Quantitation Limit is the lower calibration concentration.

ND = Not detected above the listed specified reporting limit (QL).


CAS Number = Chemical Abstract Service Number is an unique identifier of the chemical tested.

[^] = "PASS", indicates that the parameter tested meets EPA, State, or local jurisdiction MCL. "Exceeds" indicates EPA secondary limit (Aesthetic) was exceeded. "Fail" indicates EPA Primary limit (Health) was exceeded.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through OR DEQ or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

29400 Santiam Hwy.
Lebanon, OR 97355
541-367-2560
jonesdrilling@hotmail.com

[illegible]

Average Gallons Per Minute for 4 hours: 10.79 GPM


Jones Pump Company

29400 Santiam Hwy.

Lebanon, OR 97355

541-367-2560

jonesdrilling@hotmail.com



Name: Dennis Hand 05/05/2023
Address: Larwood Dr. / Zeleny Rd.
Scio, OR 97374

WELL HEAD INSPECTION

- | | | |
|---|------------------------|----|
| 1. Well vent | Yes | No |
| 2. Electrical grounded well head | Yes | No |
| 3. Cement around casing to ground level | Yes | No |
| 4. Wire in conduit | Yes | No |
| 5. Sanitary seal on well | Yes | No |
| 6. Pressure relief valve | Yes | No |
| 7. Casing size | 4" | 6" |
| 8. Casing height 12" or better | Yes | No |
| 9. If not 12" or better, what is casing height? | 3-1/2" above concrete | |
| 10. Where is the well located? | Pump house near garage | |
| 11. Well ID# (if available) | | |

WATER SYSTEM INFORMATION

- | | | | | |
|---|-------------|---------------|---------------------|-----------------|
| 1. Pressure tank | Type | well x trol | Size | 86 |
| 2. Where is the pressure tank located? | Pump house | | | |
| 3. Pressure gauge? | Yes | No | | |
| Is pressure gauge in good working order | Yes | No | | |
| 4. Hose bib close to tank | Yes | No | | |
| 5. Pressure switch setting | 40/60 | | | |
| 6. Pressure switch condition | Excellent | Good | Fair | Poor |
| 7. Pump type | Submersible | Centrifugal | Jet | |
| 8. Horse power of pump | 1/2 | Volts of pump | 220 | |
| 9. What type of pipe is in the well? | Galvanized | P.V.C. | Poly | Pipe size 1-1/2 |
| 10. Is well house insulated? | Yes | No | Are pipes insulated | Yes No |
| 11. Breaker or fuse size for pump | 20 | | | |

The above information is provided to you as a courtesy, and is for informational purposes only.
The repairs listed below are suggested repairs, not necessarily required repairs or code violations.

Comments:

Jones Pump Company

29400 Santiam Hwy.
Lebanon, OR 97355
541-367-2560
jonesdrilling@hotmail.com



Date sample was taken: 05/05/2023

Customer Name: Dennis Hand

Address: Larwood Dr. / Zeleny Rd.

City: Scio State: OR Zip: 97374

WATER SOURCE AND CHARACTERISTICS

Please check the answer that best describes your water sample

The water was drawn from:	Well	City/district	Lake/reservoir/river	Other
Gallons per minute water source (if known)				
The incoming pipe size is:				
How many people in the family:				
When the sample was collected it was:	Clear	Cloudy	Colored	
The odor of the water is:	Musty	Metallic	Rotten eggs	
The stain the water makes is:	Red	Blue-Green	Black/Brown	
The visible particles in the water are:	Sand	Silt/Mud	Other	

ANALYSIS RESULTS

HARDNESS 3 gpg

Iron 0.2 ppm

pH 7.5

Total Dissolved solids 122

Other _____

Sulphur Odor Yes **No** Other _____

Is there a 11 Volt outlet in pump house, or near pressure tank? **Yes** No

wastes soap, forms scale, clogs hot water heater and pipes. 0-3 gpg soft, 3-6 gpg moderately hard, 6-9 gpg hard water, 9+ gpg extremely hard. (1gpg=17.1 ppm)
The E.P.A recommends under 0.3ppm. Over 0.3 ppm may cause red staining on plumbing fixtures and clothes.
7.0 indicates water is neutral, under 7.0 is acidic, over 7.0 is alkaline, 6.8 or under is corrosive to fixtures and piping.