

INDIVIDUAL SEWAGE DISPOSAL SYSTEM PERMIT APPLICATION AND INSPECTION REPORT

PERMIT # 3783 DATE PERMIT ISSUED 5-13-86 DATE SYSTEM INSP. 5-13-86RECEIPT # 1297

PROPERTY OWNER & ADDRESS _____

John D. Bear

TELEPHONE _____

SEWAGE CONTRACTOR Gerald Patterson

PROPERTY LOCATION

Blue Ridge Highway, left on Mulky Gap Rd.,
right at Victory Church, on right915 Hidden Lake Rd

I hereby apply for a permit to install or construct an individual sewage disposal system and agree that the system will be installed to conform to the requirements of the former Georgia Department of Public Health, Chapter 270-5-25.

I understand that final inspection is required and hereby promise to notify the Union County Health Department upon its completion and before applying final cover.

I further realize and understand that neither this permit nor the final inspection in any way guarantee the proper operations of the sewage system nor in any way confers any guarantee or warranty of any kind.

Owner or applicant's signature

5/9/86

Date

1. Type water supply:
 1. individual
 2. community
 3. public
2. 1. New system 2. Repair 3. Existing
3. Perc rate _____
4. Type facility House
5. No. of bedrooms or gallons 4
6. Subdivision: yes / no
7. Lot size 8.4 acres
8. Building line _____
9. Septic tank capacity min. 1500
10. As installed 1501
11. Dosing tank capacity _____

12. Distance S.T. from well 300
13. Min. amount of field line:
 - Ft. sq. 900 Linear ft. 300
14. Field line as installed
 - Ft. sq. 900 Linear ft. 300
15. Width of trench 36
16. Distance between trenches 10
17. Trench depth, avg. 30
18. Distance from foundation 33
19. Nearest property line
front, rear, side
20. Distance from well 400

Site: Approved; Approved conditionally; RejectedInspector: Michael PlattSystem: Approved; Approved conditionally; RejectedInspector: Michael Platt

REMARKS:

