

ATTENTION OWNER: Confidentiality  
Privilege Notice on reverse side  
of Well Owner's copy (pink)

# State of Texas WELL REPORT

Texas Department of Licensing &  
Regulation  
P.O. Box 12157  
Austin, TX 78711  
512-463-7880

1) OWNER Joel Page ADDRESS 16 Laurel Hill Austin, Tex. 78737  
(Name) (Street or RFD) (City) (State) (Zip)  
2) ADDRESS OF WELL'S LOCATION: 3 mi. S. off #79 on C.R. 334 Long.            Lat.             
County Milam (Street, RFD or other) (City) (State) (Zip) Grid # 59-17-5

## 3) TYPE OF WORK (Check):

☒ New Well ☐ Deepening  
☐ Reconditioning ☐ Plugging

## 4) PROPOSED USE (Check):

☐ Monitor ☐ Environmental Soil Boring ☒ Domestic  
☐ Industrial ☐ Irrigation ☐ Injection ☐ Public Supply ☐ De-watering ☐ Testwell  
If Public Supply well, were plans submitted to the TNRCC? ☐ Yes ☐ No

5)

## 6) WELL LOG:

Date Drilling:

Started 10-17-00Completed 10-24-00

## DIAMETER OF HOLE

| Dia. (in.)   | From (ft.) | To (ft.)   |
|--------------|------------|------------|
| <u>7 1/2</u> | Surface    | <u>10</u>  |
| <u>6 3/4</u> | <u>10</u>  | <u>720</u> |
| <u>3 7/8</u> | <u>720</u> | <u>910</u> |

## 7) DRILLING METHOD (Check):

☐ Driven  
☐ Air Rotary ☒ Mud Rotary ☐ Bored  
☐ Air Hammer ☐ Cable Tool ☐ Jetted  
☐ Other           

From (ft.) To (ft.) Description and color of formation material

0 - 38 Clay  
38 - 39 Coal  
39 - 101 Shale  
101 - 107 Sand & Shale  
107 - Rock  
107 - 122 Shale  
122 - 133 Sand  
133 - 162 Sand Shale & Coal  
162 - 163 Rock  
163 - 320 Shale & Coal  
320 - 333 Sand (B)  
333 - 360 Shale & Coal

(Use reverse side of Well Owner's copy, if necessary)

## 8) Borehole Completion (Check):

☐ Open Hole ☐ Straight Wall  
☐ Underreamed ☐ Gravel Packed ☒ Other 4" x 2 1/2"  
If Gravel Packed give interval from            ft. to            ft.

## CASING, BLANK PIPE, AND WELL SCREEN DATA:

| Dia. (in.) | New or Used | Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial | Setting (ft.) |            | Gage Casting Screen |
|------------|-------------|----------------------------------------------------------------------|---------------|------------|---------------------|
|            |             |                                                                      | From          | To         |                     |
| <u>4</u>   | <u>N</u>    | <u>PVC</u>                                                           | <u>41</u>     | <u>700</u> |                     |
| <u>2</u>   | <u>N</u>    | <u>Galv.</u>                                                         | <u>696</u>    | <u>885</u> |                     |
| <u>2</u>   | <u>N</u>    | <u>S.S. U.B. Screen</u>                                              | <u>885</u>    | <u>900</u> | <u>.020</u>         |
| <u>2</u>   | <u>N</u>    | <u>Galv</u>                                                          | <u>900</u>    | <u>910</u> |                     |

## 9) CEMENTING DATA

Cemented from 0 ft. to 10 ft. No. of sacks used 3  
400 ft. to 700 ft. No. of sacks used 30  
Method used Grout + Pressure  
Cemented by Brien Water Wells  
Distance to septic system field lines or other concentrated contamination 150 ft.  
Method of verification of above distance Stepped

13) ☐ Well plugged within 48 hours

| Casing left in well: |         | Cement/bentonite placed in well: |         | Sacks used: |
|----------------------|---------|----------------------------------|---------|-------------|
| From (ft)            | To (ft) | From (ft)                        | To (ft) |             |
|                      |         |                                  |         |             |
|                      |         |                                  |         |             |

## 14) TYPE PUMP:

☐ Turbine ☐ Jet ☒ Submersible ☐ Cylinder  
☐ Other           

Depth to pump bowls, cylinder, jet, etc., 260 ft.

## 15) WELL TESTS:

Type test: ☐ Pump ☐ Bailer ☐ Jetted ☒ EstimatedYield: 40 gpm with 200 ft. drawdown after 2 hrs.

## 16) WATER QUALITY:

Did you knowingly penetrate any strata which contained undesirable constituents?

☐ Yes ☒ No If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water?            Depth of strata           

Was a chemical analysis made? ☐ Yes ☒ No

## 10) SURFACE COMPLETION

☐ Specified Surface Slab Installed  
☐ Specified Steel Sleeve Installed  
☐ Pillbox Adapter Used  
☒ Approved Alternative Procedure Used

## 11) WATER LEVEL:

Static level 147 ft. below land surface Date 10-24-00  
Artesian flow            gpm. Date           

## 12) PACKERS:

Type Depth

1 - 4" x 2 1/2" RXL K-Packer 696'  
1 - Burlap 843'

I certify that I drilled this well (or the well was drilled under my direct supervision) and that each and all of the statements herein are true and correct. I understand that failure to complete items 1 thru 16 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Brien Water WellsWELL DRILLER'S LICENSE NO. 52000 WI

ADDRESS Rt. 1 Box 702 Hearne Texas 77859  
(Street or RFD) (City) (State) (Zip)

(Signed) Donald Cooper  
(Licensed Well Driller)

(Signed)             
(Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

ATTENTION OWNER, CHAIRMAN OF THE BOARD  
Strategic Media Corporation  
10000 Wilshire Blvd., Suite 1000  
Beverly Hills, CA 90210

## Reporting of Well

[illegible]

of your wells will

*[The page contains faint, illegible markings and bleed-through from the reverse side.]*