

OFFICE OF THE STATE ENGINEER
COLORADO DIVISION OF WATER RESOURCES
818 Centennial Bldg., 1313 Sherman St., Denver, Colorado 80203
(303) 866-3581

LIC

WELL PERMIT NUMBER 262693
DIV. 1 WD 9 DES. BASIN MD

APPLICANT

Lot: B Block: Filing: 3 Subdiv: BEAR MOUNTAIN VISTA

THOMAS & VIRGINIA BOSCHEN
5276 BEAR MOUNTAIN DR
EVERGREEN, CO 80439-

(303) 674-3438

APPROVED WELL LOCATION

JEFFERSON COUNTY
NE 1/4 NE 1/4 Section 13
Township 5 S Range 71 W Sixth P.M.

DISTANCES FROM SECTION LINES

600 Ft. from North Section Line
1100 Ft. from East Section Line

UTM COORDINATES (Meters, Zone: 13, NAD83)

Easting: Northing:

PERMIT TO CONSTRUCT A WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
 - 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
 - 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a residential site of 8.59 acre(s) described as the northwesterly portion of tract B, unit 3, Bear Mountain Vista Subdivision, Jefferson County.
 - 4) The use of ground water from this well is limited to ordinary household purposes inside one single family dwelling. The ground water shall not be used for irrigation or other purposes.
 - 5) The pumping rate of this well shall not exceed 15 GPM.
 - 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
 - 7) This well shall be constructed not more than 200 feet from the location specified on this permit.
- NOTE: Expired permit no. 106396 was previously issued for this lot.

PS 4-7-2005

APPROVED
PAT

State Engineer

By

Receipt No. 0533494

DATE ISSUED 04-07-2005

EXPIRATION DATE 04-07-2007