



Computer#:	Fee Paid:
Receipt #	Date 05/09/2023
Jurisdiction	

Nez Perce County
215 10th Street
Lewiston, ID 83501
(208) 799-3100
Fax (208) 799-0349

Latah County
333 E Palouse River Drive
Moscow, ID 83843
(208) 882-7506
Fax (208) 882-3494

Clearwater County
105 115th Street
Orofino, ID 83544
(208) 476-7850
Fax (208) 476-7494

Idaho County
903 West Main
Grangeville, ID 83530
(208) 983-2842
Fax (208) 983-2845

Lewis County
132 N Hill Street
PO Box 277
Kamiah, ID 83536
(208) 935-2124
Fax (208) 935-0223

☒ **Speculative Site Evaluation**

☐ **Preliminary Soil Analysis for Proposed Subdivision**

Property Map showing property lines required with application.

Applicant Name:			Property Address: SHANONDOAH THIRD ST Vacant land on old school house rd		
Property Owner Name: NICK RAITHEL			City: KAMIAH	State: ID	Zip: 83536
Mailing Address: 12128 DIVISION ST STE 443			Township: 34N	Range: 4E	Sec.: 35
City: SPOKANE	State: WA	Zip: 99218	Subdivision: Lot: Block:		
Ph: (509) 368-7217		Cell:	Proposed Usage: <input checked="" type="checkbox"/> Residential <input type="checkbox"/> Non-Residential:		
Parcel #: RP34N04E356610A		<input type="checkbox"/> Private Water well <input type="checkbox"/> Public/Shared		Lot Size: 5	

I, the undersigned applicant, understand that this evaluation only indicates potential suitability of soils and site conditions for on-site sewage disposal system(s). Approval to construct a sewage disposal system(s) can only be granted by a valid septic permit. I hereby authorize the health authority to have access to this property for the purpose of performing the requested services.

Applicant Signature: _____ Date: 05/10/2023 ☐ Owner ☐ Contractor ☐ Legal Agent

Refer to attached Plot Plan and/or Soil Log Sheet for additional information and test hole data.

NO.1 Test Hole	NO.2 Test Hole	NO.3 Test Hole
0-12" – Topsoil	0-14" – Topsoil	
12-40" – B-2	14-24 – B-2	
40-70" 15% Rock – C-1	24-63" – C-1	

NO.4 Test Hole	NO.5 Test Hole	NO.6 Test Hole

Evaluation comments and/or recommendations : Only EH and Irwin Excavation was on property at time of site eval. Property lines were in question. Location of possible septic was guessed at. GPS marked test holes. Both test hole locations are suitable for septic depending on size of building. More test holes may be required if future septic is placed away from previously dug test holes. Inspection completed in an open field at the end of the makeshift driveway. Lot is sloped in locations. Heavily treed in spots.

Environmental health Specialist: Jennifer Moore Date: 05/10/2023