WV STATE DEPARTMENT OF HEALTH Office of Environmental Health Services ENVIRONMENTAL ENGINEERING DIVISION

prizob

WELL COMPLETION REPORT

3-17-200%	County Hail	nashire Permit #: OW-1	4-06-244
		on Potornac Highland Farms of	
TRAVIS	_ Area Name/Locati	Address: P.O. BOX 9 Lo	+48
Veli Owner: 304-492-5440		LEVELS, WY 2	5431
Yell Driller: Bow SMITH WELL PRILLI		NG 440 P.O. BOX 440	Si
Vell Driller:		SPRINGFIELD, W	JV 26763
elephone Number:	16-7111		
WELL LOG			
DEPTH IN FEET FORMATIONS: KIND, THICKNESS, AND IF WATER BEARING		REMARKS:	
0-4 Sandy dint + Rocks		Type of Well: D/W Drilling Method Well Diameter: Casing O.D.:	1. Air Rotary
4-16 Light Brown Shale		Well Diameter: Casing O.D.:	6 3/8"
16-37 Gray-Sandstone		Well Benth: 360 - Date Complete	d: -3 - 1 1 - 2000
37-51 Red Sandstone		CASING: Length 50 Feet Height abo	ove ground Feet
51-360 Layers of Red+		Steel Plastic	
Gray Sandstone		Other	
0.49		Туре	
		SCREEN	
		None Installed	
		Type Diameter	
	0	Slot/Gauge Length	
		Set Between Ft. and	FI
		Set Between	
PUMPING OR BAILING TEST	#1 #2 #3	WELL HEAD Pitless Adapter: Type, Make, Etc	
DETAILS	4.	Well Cap: Type, Make, Etc.	
Static Water Level (Ft. Below Grade)	90	4	
Pumping Rate (GPM)	4	Well Seal: Type, Make, Etc.	
Pumping Level (Ft Below Grade)	328	Well Platform:	Thickness
Duration of Test (In Hours)	2	Length Width	_ Illiculess
Recovery Time to Static Level (In Hours) 3	Grouting: Yes D No All Public Water Supplies must be grouted.	
	d constructed under 0	ny supervision, in compliance with all requirements of the ref	erenced permit, and that this recor
l hereby certify that this well was drilled an is true to the best of my knowledge and b	elief.		
4°0 = 134 4 GFM		Name B.W. Smith Well Urilling	Certification No.
		B.W. Smith Well brilling	
		Registered Business Name	3-17-2006
		Signed	Date