

T-010 P0002

F-012

07-30-12 15:07 FROM-

SS-137
Revised 1-73WEST VIRGINIA
SEPTIC TANK INSPECTION FORM

Hampshire County Health Department

Installation Permit No. 5T-14-77-246

Name of Owner

KNODEL, ADOLPH

Address

HILLSBORD ROAD, PURGETTSVILLE, MARYLAND

Property Address

TWIN RIDGE SUB-DIVISION - LOT NO. 3, 7 MILES SOUTH OF JUNCTION, W.V.

DESCRIPTION & NUMBER OF UNITS SERVED

Type Facility Served

HOUSE TRAILER

No. Water Closets

1

Lot Size

6 1/2 ACRES

sq. ft.

Area suitable for sewage disposal installation 25,000 sq. ft.

Source of Water Supply

DRILLED WELL

No. Lavatories

1

No. Bedrooms

2

No. Showers or Tubs

1

No. Baths

1

No. Garbage Grinders

0

No. Automatic Washers

1

SEPTIC TANK

Material CONCRETE Length x Width x Depth = cubic feetLiquid Depth ft. Liquid Capacity 1,000 gal.Distance to: Dwelling 50' Water Supply 100' Nearest Property Line 300' PLUS

SOIL ABSORPTION SYSTEM

Type Drain Line Material PLASTIC Trench Width 36 ~~24~~ InchesTrench Depth 30 Inches Total Absorption area in Trench Bottom 600 sq. ft.Diameter of Drain Line 4 Inches Type Filter Media GRAVELNo. of Drain Lines 2 Depth Filter Media Under Drain Line 6 InchesLength of Each Line 100', 100', ft. Depth Filter Media Over Drain Line 2 in.Distance of Disposal Field to: (a) Dwelling 70'(b) Water Supply 120' (c) Nearest Property Line 300' PLUS

An inspection of the septic tank system described herein disclosed that said system (MEETS, DOES NOT MEET) the minimum standards established by the West Virginia State Department of Health.

Date

NOV. 15, 1977

Sanitarian

C. Bright

SKETCH OF SYSTEM TO BE DRAWN ON BACK

Note: Copy of this inspection report must be given to owner and the original filed in the Health Department files. PERMANENT RECORD - DO NOT DESTROY.