

FORM NO. GWS-31 11/90		WELL CONSTRUCTION AND TEST REPORT STATE OF COLORADO, OFFICE OF THE STATE ENGINEER		For Office Use only	
1. WELL PERMIT NUMBER <u>249449</u>				DEC 18 2003	
2. OWNER NAME(S) <u>ROBERT A. GERREN</u> Mailing Address <u>206 WOLFE AVE</u> City, St. Zip <u>COLORADO SPRINGS CO. 80906</u> Phone <u>(719) 633-4326</u>				WATER RESOURCES STATE ENGINEER COLO. 0508362	
3. WELL LOCATION AS DRILLED: <u>SW 1/4 NE 1/4, Sec. 2 Twp. 27 S, Range 71 W 6TH PM</u> DISTANCES FROM SEC. LINES: <u>1950</u> ft. from <u>NORTH</u> Sec. line, and <u>2350</u> ft. from <u>EAST</u> Sec. line, OR (north or south) (east or west) SUBDIVISION: _____ LOT _____ BLOCK _____ FILING(UNIT) _____ STREET ADDRESS AT WELL LOCATION: _____					
4. GROUND SURFACE ELEVATION <u>6200</u> ft. DRILLING METHOD <u>ROTARY AIR</u> DATE COMPLETED <u>10/21/03</u> TOTAL DEPTH <u>225</u> ft. DEPTH COMPLETED <u>226</u> ft.					
5. GEOLOGIC LOG: Depth Description of Material (Type, Size, Color, Water Location) <u>0-3 SOIL</u> <u>3-10 ROCK CLAY</u> <u>10-30 CLAY SAND</u> <u>30-50 GRAVEL</u> <u>50-60 CLAY</u> <u>60-225 SAND ROCK CLAY Redd</u> <u>WATER 180</u>		6. HOLE DIAM. (In.) From (ft) To (ft) <u>9 3/4</u> <u>0</u> <u>60</u> <u>7 7/8</u> <u>60</u> <u>225</u>			
		7. PLAIN CASING OD (In) Kind Wall Size From(ft) To(ft) <u>8 1/2</u> <u>STEEL</u> <u>250</u> <u>0</u> <u>60</u> <u>5 1/2</u> <u>PVC</u> <u>1 1/4 INCH</u> <u>10</u> <u>80</u> PERF. CASING: Screen Slot Size: <u>1 1/2 INCH</u> <u>5 1/2" PVC</u> <u>1 1/4 INCH</u> <u>80</u> <u>225</u>			
		8. FILTER PACK: Material _____ Size _____ Interval _____		9. PACKER PLACEMENT: Type _____ Depth _____	
REMARKS: _____		10. GROUTING RECORD: Material Amount Density Interval Placement <u>CEMENT 10SK SLURRY</u> <u>39</u> <u>POURd</u>			
11. DISINFECTION: Type <u>BLACH</u> Amt. Used <u>4 CUP</u>					
12. WELL TEST DATA: ☐ Check box if Test Data is submitted on Supplemental Form. TESTING METHOD _____ Static Level <u>4</u> ft. Date/Time measured <u>10/21/10:00</u> Production Rate <u>40</u> gpm. Pumping level <u>220</u> ft. Date/Time measured <u>10/21/1:00</u> Test length (hrs.) <u>1 HR</u> Remarks _____					
13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. (Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.) CONTRACTOR <u>ROBERT PFAFFENHAUSER</u> Phone <u>(719) 246 2981</u> Lic. No. <u>955</u> Mailing Address <u>PO BOX 843 WALSBURG COLO 81089</u> Name/Title (Please type or print) <u>TIMBERLINE DRILLING</u> Signature <u>Robert Pfaffenhauser</u> Date <u>10/21/03</u>					