

Georgia Department of Human Resources On-Site Sewage Management System Inspection Report

2
G20

County Fayette	Construction Permit 056-06-OSSM-043901	Atu Type Infiltrator-Quick 4 High Capacity	Product Info 4	Health Dist 4	Date 9/21/2006
--------------------------	--	--	--------------------------	-------------------------	--------------------------

Property Location Annelise Park Lot 18 (Renewal) 300 Annelise Park Dr Fayetteville, GA 30214	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">Property Owner John Ryckley</td> <td style="width: 50%;">County Fayette</td> </tr> <tr> <td colspan="2">Sewage Disposal Contractor Holtzclaw Construction</td> </tr> </table>	Property Owner John Ryckley	County Fayette	Sewage Disposal Contractor Holtzclaw Construction	
Property Owner John Ryckley	County Fayette				
Sewage Disposal Contractor Holtzclaw Construction					

All Items: Blank = not applicable: 0 = unknown

Section A - General					
1. Type Water Supply: (1) Public (2) Community (3) Individual	1	3. Filter Type - Zabel A-100		e. Number of trenches:	1
2. House Structure: (1) New (2) Existing < 1yr. (3) Existing > 1yr	1	4. Septic tank material: (1) Precast concrete (2) Poured in place (3) Other	1	f. Distance between trenches:	9
3. Sewage Disposal Installation: (1) New. (2) Repair to existing system	1	5. Dosing tank capacity in gallons:		g. Average trench depth:	48
4. If repair to existing system. Years existing system installed:	New	6. Dosing observed ?	No	h. Aggregate proper size:	
5. Percolation Rate: Minutes/Inch:		7. Grease trap capacity in gallons:		i. Aggregate proper depth:	
6. Is property part of a subdivision?	Yes	8. Distance between septic tank and well:		j. Distance from building foundation:	55
Section B - Facility		Section D - Secondary treatment			
1. Type Facility: see facility codes below	1.	1. Field Layout Method: (1) Distribution box (2) Level field (3) Serial (4) Mound (5) Other	3	k. Nearest property line: (1) Front (2) Rear (3) Right side. (4) Left side	3
2. Water Usage determined by: (1) No. of bedrooms. (2) No. of gallons	1	2. Absorption Field: (a) Total square feet:	1092	l. Distance to nearest property line:	6
3. Number of bedrooms or gallons:	5	b. Total linear feet:	364	m. Distance from privy or absorption field to well:	
Section C - Primary Treatment				Section E - Agency Time	
1. Sewage Disp Method (1) Septic Tank (2) Construction privy (3) Pit privy (4) Aerobic unit (5) Other	1	c. Length of each trench in feet:	364	1. Total inclusive time in minutes:	50
2. Septic tank capacity in gallons:	1500	d. Width of trenches in inches:	36	Section F - System Approved:	
Tank #2 Capacity	1000			Yes	


Sketch *Not To Scale

Facility Type Codes:

- (1) Residence
- (2) Apartment
- (3) Institution
- (4) Service Station
- (5) Restaurant
- (6) Church
- (7) Tourist Accomodation
- (8) Launderette
- (9) Mobile Home
- Other (Specify) _____

Other: _____

J. H. Chambers



Remarks: _System grade checked w/ rod & level.

Inspected By <i>Jeff A Kilgore</i>	Title <i>EAH</i>	Health Agency Fayette County Health Department
---------------------------------------	---------------------	---