



PERMIT TO CONSTRUCT
Onsite Wastewater System

Permit ID: OSWW032722 v1.0
County: Spartanburg

Name: Alvina Lukyanets
Type Facility: Residential
Subdivision:
Block: 3 BDRM

Site: 650 Berry Shoals Rd
Duncan, SC, 29334

Program Code: ALTERNATIVE
System Code: 001 ALTERNATIVE PROD
TM #: 5-30-11-054.00
Water Supply: Municipal

PERMIT TO CONSTRUCT SYSTEM SPECIFICATIONS

Daily Flow (gpd): 360 **Tank Sizes (gal):** Septic Tank: 1000 Pump Chamber: Grease Trap:
LTAR (g/d/ft²): 0.3 **Trenches:** Length (ft): 300 Width (in): 36 Max. Depth (in): 40 Agg. Depth (in): 12
Min Pump Capacity: GPM at ft. of Head

SPECIAL INSTRUCTIONS/CONDITIONS

THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY SCDES. ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.

Installers must contact the local SCDES office by 10:00 AM the day prior to installation in order to schedule a time for the final inspection. If a Department representative does not arrive within 30 minutes of the scheduled time, the installer may conduct the final inspection. When a contractor self-inspection occurs, the installer must complete SCDES form 3978, Approval to Operate Contractor Self-Inspection. The installer must submit the SCDES form 3978 within 2 business days of the completion of installation.

Self-installations require a pre-construction conference with a Department representative.

- All applicable setbacks set forth in Regulation 61-56 apply.
- THIS SYSTEM IS DESIGNED WITH AN ALTERNATIVE TRENCH PRODUCT. NO FURTHER REDUCTION AND MUST BE INSTALLED BY A LICENSED SEPTIC INSTALLER TO UTILIZE SPECIFIED LINEAR FOOTAGE.

PERMIT TO CONSTRUCT SYSTEM DIAGRAM

See System Diagram on page 2 of this document.

Issued/Revised By:

Summer Lambie

Date: April 18, 2025



PERMIT TO CONSTRUCT
Onsite Wastewater System

Applicant: Alvina Lukyanets
Permit ID: OSWW032722 v1.0
County: Spartanburg

PERMIT TO CONSTRUCT SYSTEM DIAGRAM

