

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

RECEIVED

STATE OF OREGON
(Please type or print)

State Well No. 275/33E-1d

State Permit No. _____

not write above this line)

(1) OWNER:

Name Ralph Killinger
Address P.O. Box 25 Princeton, OR 97724

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED:

12" Diam. from 0 ft. to 80 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used _____

Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☒ Yes ☐ No. If yes, by whom? DOMAN

Rate: 1365 gal./min. with 30 ft. drawdown after 2 hrs.

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Clay
Well sealed from land surface to 80 ft.
Diameter of well bore to bottom of seal 13 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal _____ sacks
How was cement grout placed? _____

Was a drive shoe used? ☒ Yes ☐ No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County HARNEY Driller's well number _____
SE 1/4 Section 1 T. 27S R. B3 E W.M.

Bearing and distance from section or subdivision corner

900 FT N. of S. line 80 FT W of E
LINE

(11) WATER LEVEL: Completed well.

Depth at which water was first found 19 ft.

Static level 19 ft. below land surface. Date 16 June 78

Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 12"

Depth drilled 166 ft. Depth of completed well 166 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Clay	0	18	N
Blue Clay	18	69	19
Black Clay	69	102	19
Fine Sand + Clay	102	110	19
Sand Stone	110	125	19
Sand Black Clay	125	145	19
Black Sand - Small gravel	145	160	19
160 Rock	160	162	19
Gravel - Sand	162	166	19

Work started 15 June 1978 Completed 1 July 1978

Date well drilling machine moved off of well 15 July 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Ralph Killinger Date 15 July 1978
(Drilling Machine Operator)

Drilling Machine Operator's License No. 9020

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name _____
(Person, firm or corporation) (Type or print)

Address _____

[Signed] _____
(Water Well Contractor)

Contractor's License No. _____ Date _____ 19____

(USE ADDITIONAL SHEETS IF NECESSARY)

SP-45656-119

No data matches search criteria.

Screens

No data matches search criteria.

Well Test (Click to Expand...)

Static Water Level (Click to Expand...)

Well Constructor (Click to Expand...)

Documents (Click to Expand...)