

5/20/2022

Water Analysis Report

MAIL

Linn County Public Health
501 13th Street NW
Cedar Rapids, IA 52405-3700
(319) 892-6000 Fax: (319) 892-6099

Lab Number: 71863
Collected: 05/17/22 14:00
Received: 05/17/22 15:11
Collected By: Derek
Collection Point: 1st Flr RR
Treatment:

DEREK ALTENBURG
9174 207TH AVE
ANAMOSA IA 52205


Larry Hlavacek, Manager
Administration and Finance Division

Sample Address: 9174 207th Ave, Anamosa

Results

Total Coliform NEG per 100 ml Satisfactory

Comment:

Negative (Neg) would be considered Satisfactory. Positive (Pos) coliform counts would be considered Unsatisfactory. The analytical method is COLISURE-PA.

E-Coli NEG

Comment:

E. Coliform tests equal to POS (positive) is a more specific indicator of fecal contamination. The analytical method is COLISURE-PA.

Nitrate LESS THAN 1 mg/l Satisfactory as NO3-

Comment:

Nitrate concentrations equal to or greater than 45 milligrams/liter(mg/l) are unsafe for infant feeding. The analytical method is SM4500-NO3 D.

SAMPLE COLLECTED BY NON-HEALTH DEPARTMENT PERSONNEL