

63

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

1. WELL TAG NO. D 0089022

Drilling Permit No. 901255

Water right or injection well # _____

2. OWNER: Thomas Tribble

Name _____

Address 3810 S Gulley Ave.City Boise State ID Zip 83709

3. WELL LOCATION:

Twp. 05 North ☒ or South ☐ Rge. 04 East ☒ or West ☐Sec. 32 10 acres 1/4 40 acres 1/4 160 acres 1/4Gov't Lot _____ County BoiseLat. 43 43.4108N (Deg. and Decimal minutes)Long. 116 116.7770W (Deg. and Decimal minutes)Address of Well Site Clear Creek RdCity Idaho City

(Give at least name of road - Distance to Road or Landmark)

Lot. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation ☐ Thermal ☐ Injection
☐ Other _____

5. TYPE OF WORK:

☒ New well ☐ Replacement well ☐ Modify existing well
☐ Abandonment ☐ Other _____

6. DRILL METHOD:

☒ Air Rotary ☐ Mud Rotary ☐ Cable ☐ Other Dual Rotary

7. SEALING PROCEDURES:

Seal material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method/procedure
Bentonite	0	70	1550	Pulback & Pour

8. CASING/LINER:

Diameter (nominal)	From (ft)	To (ft)	Gauge/Schedule	Material	Casing	Liner	Threaded	Welded
6	+3	360	.250	Steel	☒	☐	☐	☒

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 360

9. PERFORATIONS/SCREENS:

Perforations ☐ Y ☒ N Method _____Manufactured screen ☒ Y ☐ N Type Wire WoundMethod of installation Set & Pullback

From (ft)	To (ft)	Slot size	Number/ft	Diameter (nominal)	Material	Gauge or Schedule
358	388	14		5	Stainless	.250

Length of Headpipe 8' Length of Tailpipe 2'Packer ☒ Y ☐ N Type K

10. FILTER PACK:

Filter Material	From (ft)	To (ft)	Quantity (lbs or ft ³)	Placement method
-----------------	-----------	---------	------------------------------------	------------------

11. FLOWING ARTESIAN:

Flowing Artesian? ☐ Y ☒ N Artesian Pressure (PSIG) _____

Describe control device _____

12. STATIC WATER LEVEL and WELL TESTS:

Depth first water encountered (ft) 45 Static water level (ft) 142Water temp. (°F) 50 Bottom hole temp. (°F) _____Describe access port Sanitary Well Cap

Well test:

Drawdown (feet)	Discharge or yield (gpm)	Test duration (minutes)
248	35	60

Test method:

Pump	Bailer	Air	Flowing artesian
☐	☐	☒	☐

Water quality test or comments: Ph-8.2, TDS-130, Fe.-1.2mg/L, gpg-13

13. LITHOLOGIC LOG and/or repairs or abandonment:

Bore Dia. (in)	From (ft)	To (ft)	Remarks, lithology or description of repairs or abandonment, water temp.	Water	
				Y	N
10	0	2	Top Soil		X
10	2	55	DCG with Sand Streaks	X	
10	55	70	Granite		X
6	70	90	Granite		X
6	90	260	Granite Soft		X
6	260	272	Granite Caving, Muddy	X	
6	272	361	Granite Soft		X
6	361	388	Granite Caving	X	
6	388	390	Granite Hard		X

RECEIVED

AUG 26 2021

WATER RESOURCES
WESTERN REGIONCompleted Depth (Measurable): 390Date Started: 8/2/2021Date Completed: 8/7/2021

14. DRILLER'S CERTIFICATION:

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Cold Steel Mechanical Co. No. 793*Principal Driller Alan Winebarger Date 8/25/2021

*Driller _____ Date _____

*Operator II _____ Date _____

Operator I _____ Date _____

* Signature of Principal Driller and rig operator are required.