



ORIGINAL PERMIT APPLICANT(S)

DIANE CORREIA

APPROVED WELL LOCATION

Water Division: 2 Water District: 12
Designated Basin: N/A
Management District: N/A
County: FREMONT
Parcel Name: LDS INC UNRECORDED SURVEY
Lot: 2 Block: Filing:
Physical Address: N/A
Section 17 Township 19.0 S Range 72.0 W Sixth P.M.

Well to be constructed on specified tract of land

PERMIT TO CONSTRUCT A NEW WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT
CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-92-602(3)(b)(II)(A) as the only well on a tract of land of 35.01 acres described as that portion of the SE 1/4 of the SW 1/4 and the SW 1/4 of the SE 1/4, Sec. 17, and the NW 1/4 of the NE 1/4 of Sec. 20., Twp. 19 S, Rng. 72 W, S P.M., Fremont County, more particularly described on Exhibit A in the well permit file.
- 4) The use of ground water from this well is limited to fire protection, ordinary household purposes inside not more than three (3) single family dwellings, the watering of poultry, domestic animals and livestock on a farm or ranch and the irrigation of not more than one (1) acre of home gardens and lawns.
- 5) The pumping rate of this well shall not exceed 15 GPM.
- 6) The return flow from the use of this well must be through an individual waste water disposal system of the non-evaporative type where the water is returned to the same stream system in which the well is located.
- 7) Pursuant to Rule 6.2.3 of the Water Well Construction Rules, the well construction contractor shall submit the as-built well location on work reports required by Rule 17.1 within 60 days of completion of the well. The measured location must be accurate to 200 feet of the actual location. The location information must include a GPS location (UTM coordinates) pursuant to the Division of Water Resources' guidelines.

NOTE: This permit will expire on the expiration date unless the well is constructed by that date. A Well Construction and Yield Estimate Report (GWS-31) must be submitted to the Division of Water Resources to verify the well has been constructed. An extension of the expiration date may be available. Contact the DWR for additional information or refer to the extension request form (GWS-64) available at: <http://www.water.state.co.us>

NOTICE: This permit has been approved subject to the following changes: The Sections that this parcel is located in were determined from mapping software used by this office and information obtained from the Fremont Count Assessor's office. You are hereby notified that you have the right to appeal the issuance of this permit, by filing a written request with this office within sixty (60) days of the date of issuance, pursuant to the State Administrative Procedures Act. (See Section 24-4-104 through 106, C.R.S.)

NOTE: Per this office's mapping software, this parcel is located in the SW 1/4 of the SE 1/4, the SE 1/4 of the SW 1/4 of Section 17, and the NW 1/4 of the NE 1/4 of Section 20, Township 19 South, Range 72 West of the Sixth Principal Meridian. The well may be constructed anywhere on the parcel.

WELL PERMIT NUMBER 309749-

RECEIPT NUMBER 3686304



Date Issued: 6/12/2018

Expiration Date: 6/12/2020

Issued By GEOFFREY DAVIS